

Table of Contents

Solution 1

LS MECAPION : SafeOP 전환 실패

× LS MECAPION Driver 연결 시 PreOP → SafeOP 전환이 안됨.

ls, mecapion, =====Case, 1=====, <callout, type=question, icon=true, title=Cause>, *, XML, ((LS, Mecapion, L7N V0.03e.xml))에서, SM2,, SM3의, Enable=0으로, 되어, 있음, <btn, type=primary, size=sm, modal=modal-large>Config, Info</btn>, <modal, id=modal-large, size=lg, title=MoreInfo>, ls mecapion op전환실패.png

</modal> </callout>

Solution

- Enable="1"로 변경

From:

<https://www.comizoa.com/info/> - -

Permanent link:

https://www.comizoa.com/info/doku.php?id=platform:ethercat:70_users_guide:20_ts:ls_safeop_failed&rev=1540971980

Last update: **2024/07/08 18:22**